



# Ameya Agencies

ENGINEERING & FIRE SAFETY SOLUTION



Office : 215, Chhatrapati Nagar, Near M.S.E.B. Switch yard, Ring Road, Nagpur-440015 Ph.: 0712-2250779  
Call : 08956623670, 09372072043, 09579285308 E-mail: contact@ameyafire.com, ameyafire@yahoo.com Visit us at: www.ameyafire.com

License no.  
MFS - LA/RF- 363  
MFS - LA/RD-538  
MFS-LA/RP- 81

Date: 05/01/2026

## Inspection Certificate of fire Prevention and Life Safety Measure (FORM-B)

To,  
The Chief Fire Officer,  
NMC.  
Nagpur

**Certified that** We have carried out inspection of the Fire Prevention and Life Safety Measures installed in the Hospital building of "**Shri Ayurved Mahavidyalaya & Pakwasa Samanvaya Rugnalaya, Hanuman Nagar Nagpur.**

We further certify that these installations in the above mentioned hospital building are maintained in good repair and efficient conditions during the **period 1<sup>st</sup> Jan 2026 - 30<sup>th</sup> June 2026** required under the provisions of the Maharashtra Fire Prevention and Life Safety Measures Act, 2006 (Mah III of 2007).

The details of the inspection of installations carried out by us are mentioned in the report appended herewith.

Form B is issued only for the maintenance of fire work carried out in the above mentioned building is not related with any construction their in.

**Note - Provide Permanent Arrangement for fill the fire Tank . It should not be empty anyway .**

For Ameya Agencies

Kunwar  
singh  
Bhardwaj  
Digitally signed  
by Kunwarsingh  
Bhardwaj  
Date: 2026.01.05  
20:44:03 +05'30'

Principal  
Shri Ayurved Mahavidyalaya  
Hanuman Nagar, Nagpur-24



# Ameya Agencies

ENGINEERING & FIRE SAFETY SOLUTION

Office : 215, Chhatrapati Nagar, Near M.S.E.B. Switch yard, Ring Road, Nagpur-440015 Ph.: 0712-2250779  
Call : 08956623670, 09372072043, 09579285308 E-mail: contact@ameyafire.com, ameya\_fire@yahoo.com Visit us at: www.ameyafire.com



## The details of the inspection of installation carried out by us.

Sr no	Description	Qty	Work Done	Remarks
1	Fire hydrant system which Included Hose box 30 mtrs & Pipe & Branch Pipe.	11 nos.	Maintained, Checked & tested by us.	All system is in working condition.
2	Main Fire pump 2280 LPM-01nos Fire Booster Pump 900 LPM-01 nos Jockey Pump 180 LPM-01no	03 nos.	Testing and trail	At the time of trail, pump is working properly with the help of electric supply and with the help of generator
3	Control Panel for all above pump	01nos	Maintained, Checked & Tested by us	All system is in working condition
4	Fire Extinguisher - ABC type 6 kg cap - 20 Nos	20 nos.	Checked by us	All fire extinguishers are in working condition.
5	Fire alarm system including fire hooter-14 nos., manual call point- 14 nos., Four zone control panel- 01 nos. 10 Zone control Panel - 01 No	30 nos.	Maintained, Checked & tested by us.	All system is in working condition.
6	Hose Reel Complete with pipe	10 nos.	Maintained, Checked & Tested by us.	All system is in working condition.
7	Fire Inlet 2way	02 nos	Maintained, Checked & tested by us	All system is in working condition
8	Smoke detector with Base	42 Nos	Maintained, Checked & tested by us	All system is in working condition

For Ameya Agencies

Kunwar Singh Bhardwaj  
Digitally signed  
by Kunwarsingh Bhardwaj  
Date: 2026.01.05 20:44:17 +05'30'

Principal  
Shri Ayurved Mahavidyalaya  
Manuman Nagar, Nagpur-24

Following are the fire system components installed for operation & maintenance  
 "Shri Ayurved Mahavidyalaya & Pakwasa Samanvaya Rugnalaya, Hanuman Nagar Nagpur."

Main Electrical Driven Pump	01 Nos	2280	LPM	Jockey Pump-	01 Nos	180	LPM
Underground Tank Capacity	01 No	100000	Litrs	Terrence Tank Capacity-	01 Nos	25000	Liter
Control Panel	01 Nos			Brigade Inlet Valve-	02 Nos	4 & 10	Zone
Wet Riser Cum Down Comer	01 Nos	100	MM		02 Nos	2	Way
Booster Pump	01 Nos	900	LPM	* NR = Not Required			

Sr. No.	Particular's	G										Total		
		1	2	3	4	5	6	7	8	9	10			
1	Floor Area(Sq. Mtr.)	6	3	2										
2	Landing Valve	6	3	2										
3	Hose Pipe With Coupling 30 Meter	6	3	2										
4	Hose Box	6	3	2										
5	Branch Pipe	6	3	2										
6	Hose Reel Drum With Shut Up Valve	6	3	2										
7	Extinguisher Mech Foam 45 Ltr	4	4	2										11 Nos
8	Fire door													11 Nos
9	Extinguisher ABC 5 Kg													11 Nos
10	Extinguisher Water CO2 9 Ltr	12	8	0										11 Nos
12	Manual Call Point													10 Nos
13	Hooter	6	6	2										
14	Smoke Detector	7	6	1										20 Nos
		42												14 Nos
														14 Nos
														42 Nos

License No. MFS - LA/RF-363  
 MFS - LA/RD-538  
 MFS - LA/RP-81  
 Place: Nagpur  
 Date: 5-Jan-26

Kunwar Singh Bhardwaj  
 Digitally signed by Kunwar Singh Bhardwaj  
 Date: 2026.01.05 20:46:08 +0530

Yours Faithfully

For Ameya Agencies

Principal  
 Shri Ayurved Mahavidyalaya  
 Hanuman Nagar, Nagpur-24